



Wendee Aguilar <wendddble@gmail.com>

Fwd: Grady Kohler/Wanship Water LLC well a50551

1 message

Denise Holding <deniseholding@gmail.com>
To: LRE Wendee Aguilar <Wendddble@gmail.com>

Fri, Jan 9, 2026 at 10:56 AM

Wanship water

----- Forwarded message -----

From: **Danielle Zebelean** <dzebelean@utah.gov>

Date: Tue, Jan 6, 2026 at 7:57 AM

Subject: Re: Grady Kohler/Wanship Water LLC well a50551

To: Julie Cobleigh <jjcobleigh@utah.gov>

CC: Denise Holding <deniseholding@gmail.com>, LRE Candy Rust & Rocksie <candacerust@gmail.com>, LRE Paul Strader <paul@slspropertiesolutions.com>, LRE Rosemary and Kevin <Rpcenergy@gmail.com>, LRE Wendee Aguilar <Wendddble@gmail.com>, Skyler Kershner <sk.kershner@gmail.com>, Ivan Gaichuk <igaichuk@utah.gov>, Michael Newberry <mnewberry@utah.gov>

Hi Denise,

I was previously working with Grady on getting the well approved. We have received the well driller's log and the sanitary seal certification letter from 1987 to verify it had a 100-foot grout seal originally. My understanding is the well is only drilled and has never been equipped. We recommended that they get a video of the well to see the current condition of the casing, if the video showed a need for it also to clean the well and take bacteria samples if growths were observed in the video.

As far as what is required to put the well in service in a public water system we will require the following items:

- Preliminary Evaluation Report and Drinking Water Source Protection Plan
- Pump Test of the Well
- Complete New Source Chemical Analysis
- Plans and Specifications stamped by a P.E. registered in Utah for equipping the well and the discharge piping.

Hopefully that helps! Please let me know if you have any other questions.

**Dani Zebelean, P.E.**

Environmental Engineer III | Permitting

M: (385) 278-5110**Hours:** M-Th, 7am - 5 pm

drinkingwater.utah.gov

Emails to and from this email address may be considered public records and thus subject to Utah GRAMA requirements.

On Mon, Jan 5, 2026 at 11:36 AM Julie Cobleigh <jjcobleigh@utah.gov> wrote:

Thank you, Denise. I've copied Dani Zebelean who has been working with Grady Kohler on the requirements for getting after-the-fact approval for this well. She will provide a summary of where things are at and what is needed.



Julie Cobleigh, P.E.

District Engineer | Wasatch Back

M: (385) 214-9770

deq.utah.gov

Emails to and from this email address may be considered public records and thus subject to Utah GRAMA requirements.

----- Forwarded message -----

From: **Denise Holding** <deniseholding@gmail.com>

Date: Mon, Jan 5, 2026 at 11:32 AM

Subject: Grady Kohler/Wanship Water LLC well a50551

To: Department Of Drinking Water Julie COBLEIGH <jjcobleigh@utah.gov>

Cc: LRE Candy Rust & Rocksie <candacerust@gmail.com>, LRE Paul Strader <paul@slspropertiesolutions.com>, LRE Rosemary and Kevin <Rpcenergy@gmail.com>, LRE Wendee Aguilar <Wenddbble@gmail.com>, Skyler Kershner <sk.kershner@gmail.com>

Hi good morning Julie,

Thank you so much for taking the time this morning to speak with me about the Wanship Water well that's located on the west side of 32.

If you could please email me the information you gave me this morning plus any updated information that would be great.

I have included the Lake Rockport Estates Water committee in this email as well

Thank you so much for your help!

Kind regards,

Denise Holding

LRE Water committee chairman